

— METASYS —																		
Technol. system	Inf. bod Short Description		Popis Description Long	Hardware Object	Type of Controller	HW	SW Item	Type of Signal	Range Low	Range High	Jednotky Unit	State 0 (OPEN)	State 1 (CLOSED)	Normal State	Alarm Priority	Panel	Poznámka Notice	
VZT	TT51		Teplota nasavaná	RM1OM4711-3	IOM4711	IN-UN	IN1	Pt1000	-40	50	°C					RM1		
VZT	PdAH12		Filtr odvod 2	RM1OM4711-3	IOM4711	IN-UN	IN2					ALARM	NORMAL			RM1		
VZT				RM1OM4711-3	IOM4711	IN-UN	IN3									RM1		
VZT				RM1OM4711-3	IOM4711	IN-UN	IN4									RM1		
VZT	ST		Mrazová ochrana	RM1OM4711-3	IOM4711	IN-UN	IN5					ALARM	NORMAL			RM1		
VZT	PK1.1		Signalizace polohy PK1.1	RM1OM4711-3	IOM4711	IN-UN	IN6					ALARM	NORMAL			RM1		
VZT	PK1.2		Signalizace polohy PK1.2	RM1OM4711-3	IOM4711	IN-BIN	IN7					ALARM	NORMAL			RM1		
VZT	Eps		signál EPS	RM1OM4711-3	IOM4711	IN-BIN	IN8					ALARM	NORMAL			RM1		
VZT				RM1OM4711-3	IOM4711	OUT-BIN	OUT1									RM1		
VZT				RM1OM4711-3	IOM4711	OUT-BIN	OUT2									RM1		
VZT				RM1OM4711-3	IOM4711	OUT-BIN	OUT3									RM1		
VZT1				RM1OM4711-3	IOM4711	OUT-CO	OUT4									RM1		
VZT1				RM1OM4711-3	IOM4711	OUT-CO	OUT5									RM1		
VZT1				RM1OM4711-3	IOM4711	OUT-CO	OUT6									RM1		
VZT1				RM1OM4711-3	IOM4711	OUT-CO	OUT7									RM1		
VZT1				RM1OM4711-3	IOM4711	OUT-AN	OUT8									RM1		
VZT1				RM1OM4711-3	IOM4711	OUT-AN	OUT9									RM1		

	<b>Akce:</b> <b>VZT ARO</b> <b>Nemocnice Jindřichův Hradec</b>	<b>DATA POINT LIST</b> Soubor:		RM1	Datum:	02/21	Část:	
			IOM4711		Oprava:		Strana:	4